

Report.

70650051-TDT 07-64298A

Type tests concerning a 245 kV cable,
manufacturer Phelps Dodge Thailand Ltd.,
Bangkok, Thailand

Arnhem, 16 January 2008



INSPECTION REPORT

Report number 70650051-TDT 07-64298A
Client Pfisterer Ixosil Ltd
Power Cable Systems
CH-6460 Altdorf, Switzerland

Reference 13720

Concerning Type tests
Date August 2006 till January 2008
Place Altdorf, Switzerland and Bangkok, Thailand
Object 245 kV cable
Manufacturer Phelps Dodge Thailand Ltd., Bangkok, Thailand

REQUIREMENTS

The requirements of standard IEC 62067 (2001-10).

TEST PROGRAMME

The programme was specified by the client and comprised all type tests mentioned in standard IEC 62067 (2001-10).
For the programme reference is made to page 5.

SUMMARY AND CONCLUSION

The test results obtained relate only to the work ordered and to the material tested.
The cable met the requirements.

Author J.W. Vermeer

This report consists of:
25 pages incl. 6 annexes (13 pages)

KEMA Nederland B.V.

P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Arnhem, 16 January 2008